


Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Direktor: Prof. Dr. rer. nat. L. Dunemann

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V.

Hygiene-Institut, UMWELT Postfach 10 12 55 · 45812 Gelsenkirchen



Rotthauer Str. 21
45879 Gelsenkirchen

Telefon (0209) 9242-0
Telefax (0209) 9242-222
Internet www.hyg.de

Unser Zeichen: W-281222ze-17-WD
Ansprechpartner: F. Wedke B. Eng.

Test - certificate

hygiene – conformity check to the design requirements of selected technical guidelines

Test institute:	Hygiene Institut des Ruhrgebiets Institut für Umwelthygiene und Toxikologie Rotthauer Straße 21 49879 Gelsenkirchen
Test object:	fire damper "CU-LT"
Manufacturer:	Rf-Technologies Lange Ambachtstraat 40 9860 Oosterzele Belgium
Basis of the examination:	✓ VDI 6022, part 1 (01/2018) ✓ VDI 3803, part 1 (02/2010) ✓ DIN 1946, part 4 (12/2008) ✓ ÖNorm H 6021 (08/2016) ✓ ÖNorm H 6020 (03/2015) ✓ SWKI VA104-01 (04/2006) ✓ SWKI VA105-01 (07/2015)
Validity period:	05/2018 – 05/2023
Test report:	W-281222-17-WD



In conclusion it can be stated that the examined fire dampers „CU-LT“, as specified in the test report W-281222-17-WD, are in compliance with the constructive demands relevant for hygiene of the above mentioned regulations.

(Priv.-Doz. Dr. G.-J. Tuschewitzki)
Head of the Department of Water
Hygiene and Environmental
Microbiology

(F. Wedke B. Eng.)
Section head of Air Conditioning technology
Department of Water Hygiene and Environmental
Microbiology

issued 11.05.2018, Gelsenkirchen